



APPROVALS®

Certificate of Suitability

Certificate No.: SAA230248

Certificate Holder: BOKE Drivers Co., Ltd.
2nd and 3rd Floor, No.51, Xihuan 5th Road,
South District, 528455 Zhongshan City,
Guangdong
P.R. China

Regulatory Definition: Non-Prescribed

Product Description: Non-isolated Constant Current LED Driver
(Built-in Type, Auto-wound, Constant Current)

Standard /s: AS 61347.2.13:2018
AS/NZS 61347.1:2016 Inc A1

Condition /s: Must comply with Standard requirements of end product
when installed.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA230248

Initial Issue Date: 2 March 2023

Expiry Date: 2 March 2028

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 1 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0450AS	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.25A/0.3A/0.35A, 50W/60W/70W, 240Vdc Max Output: 100-188Vdc, 0.4A, 75.2W, 240Vdc Max Output: 100-165Vdc, 0.45A, 74.25W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0400AS	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.2A/0.25A/0.30A/0.35A, 40W/50W/60W/70W, 240Vdc Max Output: 100-188Vdc, 0.4A, 75.2W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0300AS	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.33A Max Output: 100-200Vdc, 0.15A/0.2A/0.25A/0.3A, 30W/40W/50W/60W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0450AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.45A, 74.25W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0440AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.44A, 72.6W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0430AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.43A, 70.95W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0420AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.42A, 69.3W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0410AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.41A, 67.65W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 2 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0400AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.4A, 75.2W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0390AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.39A, 73.32W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0380AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.38A, 71.44W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0370AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.37A, 69.56W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0360AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.36A, 67.68W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0350AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.35A, 70W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0340AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.34A, 68W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0330AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.33A, 66W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0320AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.32A, 64W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0310AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.31A, 62W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 3 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0300AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.3A, 60W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0290AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.29A, 58W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0280AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.28A, 56W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0270AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.27A, 54W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0260AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.26A, 52W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0250AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.25A, 50W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0240AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.24A, 48W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0230AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.23A, 46W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0220AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.22A, 44W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0210AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.21A, 42W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 4 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0200AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.2A, 40W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0190AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.19A, 38W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0180AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.18A, 36W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0170AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.17A, 34W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0160AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.16A, 32W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0150AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.15A, 30W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0140AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.14A, 28W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0130AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.13A, 26W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0120AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.12A, 24W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0110AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.11A, 22W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 5 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0100AR	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.1A, 20W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0450A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.45A, 74.25W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0440A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.44A, 72.6W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0430A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.43A, 70.95W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0420A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.42A, 69.3W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0410A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-165Vdc, 0.41A, 67.65W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0400A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.4A, 75.2W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0390A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.39A, 73.32W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0380A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.38A, 71.44W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0370A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.37A, 69.56W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 6 of 9



APPROVALS®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0360A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-188Vdc, 0.36A, 67.68W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0350A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.35A, 70W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0340A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.34A, 68W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0330A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.33A, 66W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0320A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.32A, 64W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0310A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.31A, 62W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0300A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.3A, 60W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0290A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.29A, 58W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0280A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.28A, 56W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0270A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.27A, 54W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 7 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0260A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.26A, 52W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0250A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.25A, 50W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0240A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.24A, 48W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0230A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.23A, 46W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0220A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.22A, 44W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0210A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.21A, 42W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0200A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.2A, 40W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0190A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.19A, 38W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0180A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.18A, 36W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0170A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.17A, 34W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 8 of 9



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating / Marking
BK-BAN075-A0160A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.16A, 32W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0150A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.15A, 30W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0140A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.14A, 28W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0130A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.13A, 26W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0120A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.12A, 24W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0110A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.11A, 22W, 240Vdc Max ta:60°C, tc:90°C
BK-BAN075-A0100A	BOKE	Input: 200-240Vac or 200-240Vdc; 0/50/60Hz, 0.4A Max Output: 100-200Vdc, 0.1A, 20W, 240Vdc Max ta:60°C, tc:90°C

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-03-23 230248
Page 9 of 9