



China

Attestation of Conformity

No. E8AUK 089086 0276 Rev. 00

Holder of Attestation: **BOKE Drivers Co., Ltd.**

2nd and 3rd Floor, No.51, Xihuan 5th Road
South District
528455 Zhongshan City, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Power supplies**
(Non-isolated Constant Current LED Driver)

This Attestation of Conformity is issued on a voluntary basis according to the Electromagnetic Compatibility Regulations 2016 relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 657402204601

Date, 2023-01-16

(Laurent Yuan)

Page 1 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA****TUV®**



China

Attestation of Conformity

No. E8AUK 089086 0276 Rev. 00

Model(s):

BK-BEN022-A0350AS; BK-BEN022-AxxxxAR;
BK-BEN022-AxxxxA; BK-BEN040-A0350AS;
BK-BEN040-AxxxxAR; BK-BEN040-AxxxxA;
BK-BEN060-A0350AS; BK-BEN060-AxxxxAR;
BK-BEN060-AxxxxA; BK-DEN075-A0450Ad;
BK-DEN075-A0450ADP; BK-DEN075-A0450ADF;
BK-DEN075-A0450ADE; BK-DEN075-A0450ADPE;
BK-DEN075-A0450ADFE; BK-DEN100-A0800Ad;
BK-DEN100-A0800ADP; BK-DEN100-A0800ADF;
BK-DEN100-A0800ADE; BK-DEN100-A0800ADPE;
BK-DEN100-A0800ADFE
(‘xxxx’=0100-0350 indicates rated output current
(I_{rated}) 0.10-0.35A, in steps of 0.01A)

Description of Object:

Rated Input Voltage: 200-240V AC/DC
Rated Frequency: 0/50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection Class: I

Tested according to:

EN IEC 55015:2019/A11:2020
EN IEC 61000-3-2:2019/A1:2021
EN 61000-3-3:2013/A2:2021
EN 61547:2009

Page 2 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TUV®



China

Attestation of Conformity

No. E8AUK 089086 0276 Rev. 00

Model No.	Rated Input Current (A) Max.	Output voltage (VDC)	I _{rated} (mA)	P _{rated} (W) Max.	U _{out} (VDC)
BK-BEN022-A0350AS	0.135	39-72	200	14.4	150
		39-72	250	18.0	
		39-72	300	21.6	
		39-65	350	22.75	
BK-BEN022-AxxxxAR; BK-BEN022-AxxxxA	0.135	39-72	100-300	21.6	150
		39-65	310-350	22.75	
BK-BEN040-A0350AS	0.225	54-114	200	22.8	150
		54-114	250	28.5	
		54-114	300	34.2	
		54-114	350	39.9	
BK-BEN040-AxxxxAR; BK-BEN040-AxxxxA	0.225	54-114	100-350	39.9	150
BK-BEN060-A0350AS	0.34	100-200	200	40.0	250
		100-200	250	50.0	
		100-200	300	60.0	
		100-172	350	60.2	
BK-BEN060-AxxxxAR; BK-BEN060-AxxxxA	0.34	100-200	100-300	60.0	250
		100-172	310-350	60.2	
BK-DEN075-A0450Ad; BK-DEN075-A0450ADP; BK-DEN075-A0450ADF; BK-DEN075-A0450ADE; BK-DEN075-A0450ADPE; BK-DEN075-A0450ADFE	0.41	54-200	100	20.0	300
		54-200	120	24.0	
		54-200	135	27.0	
		54-200	150	30.0	
		54-200	175	35.0	
		54-200	200	40.0	
		54-200	225	45.0	
		54-200	250	50.0	
		54-200	275	55.0	
		54-200	300	60.0	
		54-200	325	65.0	
		54-200	350	70.0	
		54-200	375	75.0	
		54-190	400	76.0	
BK-DEN100-A0800Ad; BK-DEN100-A0800ADP; BK-DEN100-A0800ADF; BK-DEN100-A0800ADE; BK-DEN100-A0800ADPE; BK-DEN100-A0800ADFE	0.53	54-180	425	76.5	320
		54-170	450	76.5	
		54-200	250	50.0	
		54-200	275	55.0	
		54-200	300	60.0	
		54-200	325	65.0	
		54-200	350	70.0	
		54-200	375	75.0	
		54-200	400	80.0	
		54-200	425	85.0	
		54-200	450	90.0	
		54-200	500	100.0	
		54-181	550	99.55	
		54-166	600	99.6	
		54-153	650	99.45	
		54-142	700	99.4	
		54-133	750	99.75	
		54-125	800	100.0	

Page 3 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TÜV®