



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-240395-EA

Certificate Holder: BOKE Drivers Co., Ltd.
2nd and 3rd Floor, No.51, Xihuan 5th Road,
South District, 528455 Zhongshan City,
Guangdong
P.R. China

Regulatory Definition: Power Supply or Charger

Product Description: Dimmable Constant Current LED Driver

Standard/s: AS 61347.2.13:2018
AS/NZS 61347.1:2016 Inc A1

Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-240395-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 22 March 2024

Expiry Date: 22 March 2029

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395
Page 1 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0600AD	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.225A/0.25A/0.275A/0.3A/0.35A/0.4A/0.45A/0.5A, 9.45W/10.5W/11.55W/12.6W/14.7W/16.8W/18.9W/21W, 50Vdc Max 24-40Vdc, 0.55A/22W, 50Vdc Max 24-38Vdc, 0.6A/22.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0600ADP	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.225A/0.25A/0.275A/0.3A/0.35A/0.4A/0.45A/0.5A, 9.45W/10.5W/11.55W/12.6W/14.7W/16.8W/18.9W/21W, 50Vdc Max 24-40Vdc, 0.55A/22W, 50Vdc Max 24-38Vdc, 0.6A/22.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0600ADF	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.225A/0.25A/0.275A/0.3A/0.35A/0.4A/0.45A/0.5A, 9.45W/10.5W/11.55W/12.6W/14.7W/16.8W/18.9W/21W, 50Vdc Max 24-40Vdc, 0.55A/22W, 50Vdc Max 24-38Vdc, 0.6A/22.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0600ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.6A, 22.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 2 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0595ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.595A, 22.61W, 50Vdc Max Ta:45°C, Tc:90°C
BK-DKL022-A0590ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.59A, 22.42W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0585ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.585A, 22.23W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0580ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.58A, 22.04W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0575ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.575A, 21.85W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0570ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.57A, 21.66W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0565ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.565A, 21.47W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 3 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0560ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.56A, 21.28W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0555ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-38Vdc, 0.555A, 21.09W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0550ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.55A, 22W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0545ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.545A, 21.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0540ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.54A, 21.6W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0535ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.535A, 21.4W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0530ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.53A, 21.2W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 4 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0525ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.525A, 21W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0520ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.52A, 20.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0515ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.515A, 20.6W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0510ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.51A, 20.4W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0505ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-40Vdc, 0.505A, 20.2W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0500ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.5A, 21W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0495ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.495A, 20.79W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 5 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0490ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.49A, 20.58W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0485ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.485A, 20.37W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0480ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.48A, 20.16W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0475ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.475A, 19.95W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0470ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.47A, 19.74W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0465ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.465A, 19.53W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0460ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.46A, 19.32W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 6 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0455ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.455A, 19.11W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0450ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.45A, 18.9W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0445ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.445A, 18.69W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0440ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.44A, 18.48W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0435ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.435A, 18.27W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0430ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.43A, 18.06W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0425ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.425A, 17.85W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 7 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0420ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.42A, 17.64W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0415ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.415A, 17.43W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0410ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.41A, 17.22W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0405ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.405A, 17.01W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0400ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.4A, 16.8W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0395ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.395A, 16.59W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0390ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.39A, 16.38W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 8 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0385ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.385A, 16.17W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0380ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.38A, 15.96W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0375ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.375A, 15.75W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0370ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.37A, 15.54W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0365ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.365A, 15.33W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0360ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.36A, 15.12W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0355ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.355A, 14.91W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 9 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0350ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.35A, 14.7W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0345ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.345A, 14.49W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0340ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.34A, 14.28W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0335ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.335A, 14.07W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0330ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.33A, 13.86W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0325ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.325A, 13.65W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0320ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.32A, 13.44W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395
Page 10 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0315ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.315A, 13.23W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0310ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.31A, 13.02W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0305ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.305A, 12.81W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0300ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.3A, 12.6W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0295ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.295A, 12.39W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0290ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.29A, 12.18W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0285ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.285A, 11.97W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395

Page 11 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0280ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.28A, 11.76W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0275ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.275A, 11.55W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0270ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.27A, 11.34W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0265ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.265A, 11.13W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0260ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.26A, 10.92W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0255ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.255A, 10.71W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0250ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.25A, 10.5W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395
Page 12 of 13



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
BK-DKL022-A0245ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.245A, 10.29W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0240ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.24A, 10.08W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0235ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.235A, 9.87W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0230ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.23A, 9.66W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover
BK-DKL022-A0225ADN	BOKE	Input: 200-240Vac or 200-240Vdc, 50/60Hz, 0.14A Max Output: 24-42Vdc, 0.225A, 9.45W, 50Vdc Max Ta:45°C, Tc:90°C Class II, Do-Not-Cover

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-24 240395
Page 13 of 13