



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA220012

Certificate Holder: BOKE Drivers Co., Ltd.
2nd and 3rd Floor, No.51, Xihuan 5th Road,
South District, 528455 Zhongshan City,
Guangdong
P.R. China

Regulatory Definition: Non-Prescribed

Product Description: Dimmable, Constant Current LED Driver (Built-in, SELV)

Standard/s: AS 61347.2.13:2018
AS/NZS 61347.1:2016 Inc A1

Condition/s: Must comply with Standard requirements of end product
when installed.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA220012

Initial Issue Date: 24 February 2022

Expiry Date: 24 February 2027

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 24-02-22 220012
Page 1 of 2



APPROVALS®

Certificate of Suitability

Model	Trade Name	Rating/Marking
BK-KHL040-1050Am	BOKE	Input: 200-240Vac 50/60Hz or 200-240Vdc, 0.24A Max Output: 24-42Vdc, 50Vdc Max 0.60/0.65/0.70/0.75/0.80/0.85/0.90/0.95A 25.2/27.3/29.4/31.5/33.6/35.7/37.8/39.9W 24-40Vdc, 50Vdc Max, 1.00A 40.0W 24-38Vdc, 50Vdc Max, 1.05A 39.9W EL, ta:60°C, tc:90°C
BK-KHL030-0800Am	BOKE	Input: 200-240Vac 50/60Hz or 200-240Vdc, 0.21A Max Output: 24-42Vdc, 50Vdc Max 0.35/0.40/0.45/0.50/0.55/0.60/0.65/0.70A 14.7/16.8/18.9/21.0/23.1/25.2/27.3/29.4W 24-40Vdc, 50Vdc Max, 0.75A 30.0W 24-38Vdc, 50Vdc Max, 0.80A 30.4W EL, ta:60°C, tc:90°C

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 24-02-22 220012
Page 2 of 2