



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-212871-EA

Certificate Holder: BOKE Drivers Co., Ltd.
2nd and 3rd Floor, No.51, Xihuan 5th Road,
South District, 528455 Zhongshan City,
Guangdong
P.R. China

Regulatory Definition: Power Supply or Charger
Product Description: Dimmable Constant Current LED Driver (Independent, SELV)
Trade Name/s: BOKE
Model No.: BK-KUL040-1050Am
Rating / Marking/s: Input: 200-240Vac 50/60Hz or 200-240Vdc, 0.24A Max
Output: 24-42Vdc, Max 50Vdc,
0.60/0.65/0.70/0.75/0.80/0.85/0.90/0.95/1.00A
25.2/27.3/29.4/31.5/33.6/35.7/37.8/39.9/40.0W
24-38Vdc, Max 50Vdc, 1.05A 39.9W
ta:45°C, tc: 90°C, Do not cover, EL, Class II

Standard/s: AS 61347.2.13:2018

AS/NZS 61347.1:2016 Inc A1
Condition/s: For use with lighting equipment only.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-212871-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 23 December 2021

Expiry Date: 23 December 2026

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 19-01-22 212871
Correction Page 1 of 2



A P P R O V A L S ®

Certificate of Conformity/Approval

Additional Models

BK-KUL030-0800Am

Trade Name

BOKE

Rating/Marking

Input: 200-240Vac 50/60Hz or 200-240Vdc, 0.21A Max

Output: 24-42Vdc, Max 50Vdc

0.35/0.40/0.45/0.50/0.55/0.60/0.65/0.70/0.75A

14.7/16.8/18.9/21.0/23.1/25.2/27.3/29.4/30.0W

24-38Vdc, Max 50 Vdc, 0.80A 30.4W

ta:45°C, tc:80°C, Do not cover, EL, Class II

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 19-01-22 212871
Correction Page 2 of 2