



China

Attestation of Conformity

No. N8AUK 089086 0474 Rev. 00

Holder of Attestation: **BOKE Drivers Co., Ltd.**
2nd and 3rd Floor, No.51, Xihuan 5th Road
South District
528455 Zhongshan City, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic controlgear for LED modules
(Dimmable Constant Current LED Driver)**

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment.
For details see: www.tuvsud.com/ps-cert

Test report no.: 651402400201

Date, 2024-06-07

(Taylor Yao)

Page 1 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**



China

Attestation of Conformity

No. N8AUK 089086 0474 Rev. 00

Model(s):

BK-DML022-B0600ADP; BK-DML022-B0600ADN;
BK-DML022-BxxxxADP; BK-DML022-BxxxxADN;
BK-DML040-B1100ADP; BK-DML040-B1100ADN;
BK-DML040-BxxxxADP; BK-DML040-BxxxxADN;
BK-DML060-B1650ADP; BK-DML060-B1650ADN;
BK-DML060-BxxxxADP; BK-DML060-BxxxxADN;
BK-DML080-B2200ADP; BK-DML080-B2200ADN;
BK-DML080-BxxxxADP; BK-DML080-BxxxxADN;
BK-DML150-B4000ADP; BK-DML150-B4000ADN;
BK-DML150-BxxxxADP; BK-DML150-BxxxxADN
(‘xxxx’=0100-3990 indicates rated output current
(I_{rated}) 100-3990mA, in steps of 10mA)

Brand:**BOKE****Parameters:**

Rated Input Voltage: 200-240V AC/DC
Rated Frequency: 0/50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection against Electric Shock: Class I; SELV
Degree of Protection: IP65/IP67
Method of Installation: Independent
Type of Output: Constant current type
ta: 60°C
tc: 90°C

**Tested
according to:**

EN 61347-2-13:2014/A1:2017
EN 61347-1:2015/A1:2021
EN 62493:2015/A1:2022

Page 2 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.





China

Attestation of Conformity

No. N8AUK 089086 0474 Rev. 00

Model	Rated Input Current (A) Max.	Output Voltage (VDC)	I _{rated} (mA)	P _{rated} (W) Max.	U _{out} (VDC)
BK-DML022-B0600ADP, BK-DML022-B0600ADN	0.14	12-42	100-600	22.8	50
BK-DML022-BxxxxADP, BK-DML022-BxxxxADN	0.14	12-38	550-590	22.42	50
		12-40	510-550	22.0	
		12-42	100-500	21.0	
BK-DML040-B1100ADP, BK-DML040-B1100ADN	0.25	12-42	400-1100	42.0	50
BK-DML040-BxxxxADP, BK-DML040-BxxxxADN	0.25	12-38	1060-1090	41.42	50
		12-40	1010-1050	42.0	
		12-42	400-1000	42.0	
BK-DML060-B1650ADP, BK-DML060-B1650ADN	0.37	12-42	600-1650	63.0	50
BK-DML060-BxxxxADP, BK-DML060-BxxxxADN	0.37	12-38	1560-1640	62.32	50
		12-40	1510-1550	62.0	
		12-42	600-1500	63.0	
BK-DML080-B2200ADP, BK-DML080-B2200ADN	0.55	12-42	800-2200	84.0	50
BK-DML080-BxxxxADP, BK-DML080-BxxxxADN	0.55	12-38	2110-2190	83.22	50
		12-40	2010-2100	84.0	
		12-42	800-2000	84.0	
BK-DML150-B4000ADP, BK-DML150-B4000ADN	0.86	24-42	1500-4000	152.0	50
BK-DML150-BxxxxADP, BK-DML150-BxxxxADN	0.86	24-38	3810-3990	151.62	50
		24-40	3610-3800	152.0	
		24-42	1500-3600	151.2	

Page 3 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

UK
CA