



China

Attestation of Conformity

No. E8AUK 089086 0381 Rev. 00

Holder of Attestation: **BOKE Drivers Co., Ltd.**
2nd and 3rd Floor, No.51, Xihuan 5th Road
South District
528455 Zhongshan City, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Power supplies**
(Constant Current LED Driver)

This Attestation of Conformity is issued on a voluntary basis according to the Electromagnetic Compatibility Regulations 2016 relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 657402300401

Date, 2023-04-21

(Laurent Yuan)

Page 1 of 2

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA****TUV®**



China

Attestation of Conformity

No. E8AUK 089086 0381 Rev. 00

Model(s): BK-PPL018-BxxxxA, BK-PPL022-BxxxxA,
 BK-PPL040-BxxxxA, BK-PPL050-BxxxxA,
 BK-PPL060-BxxxxA
 ('xxxx'=0150-1650 indicates rated output current
 (I_{rated}) 150-1650mA, in steps of 10mA)

Description of Object:

Rated Input Voltage: 200-240V AC/DC
 Rated Frequency: 0/50/60Hz
 Rated Input Current: See below table for details
 Rated Output: See below table for details
 Protection Class: II

Model	Rated Input Current (A) Max.	Output Voltage (VDC)	I_{rated} (mA)	P_{rated} (W) Max.
BK-PPL018-BxxxxA	0.11	28-42	150-400	16.8
		28-40	410-450	18.0
BK-PPL022-BxxxxA	0.14	28-42	150-500	21.0
		28-40	510-550	22.0
		28-38	560-600	22.8
BK-PPL040-BxxxxA	0.24	30-42	500-950	39.9
		30-40	960-1000	40.0
BK-PPL050-BxxxxA	0.29	28-42	800-1200	50.4
		28-40	1210-1250	50.0
BK-PPL060-BxxxxA	0.38	28-42	1000-1500	63.0
		28-40	1510-1550	62.0
		28-38	1560-1650	62.7

Tested according to: EN IEC 55015:2019/A11:2020
 EN IEC 61000-3-2:2019/A1:2021
 EN 61000-3-3:2013/A2:2021
 EN 61547:2009

Page 2 of 2

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

UK
CA

TUV®