



China

Attestation of Conformity

No. E8AUK 089086 0433 Rev. 01

Holder of Attestation: **BOKE Drivers Co., Ltd.**
2nd and 3rd Floor, No.51, Xihuan 5th Road
South District
528455 Zhongshan City, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Power supplies**
(Constant Current LED Driver)

This Attestation of Conformity is issued on a voluntary basis according to the Electromagnetic Compatibility Regulations 2016 relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 657402304102

Date, 2024-04-03

(Laurent Yuan)

Page 1 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Certification and Testing (China) Co., Ltd. Floor 1-4, Building B, No.37, Tuanjie Road(Middle), Xishan Economic and Technological Development Zone, Wuxi, Jiangsu, P.R. China

**UK
CA**

TÜV®



China

Attestation of Conformity

No. E8AUK 089086 0433 Rev. 01

Model(s): BK-PSL042-A1100AS; BK-PSL042-B1100AS;
BK-PSL042L-A1100AS; BK-PSL042-AxxxxA;
BK-PSL042-BxxxxA; BK-PSL042L-AxxxxA;
BK-PSL022-A0500AS; BK-PSL022L-A0500AS;
BK-PSL022-AxxxxA; BK-PSL022L-AxxxxA;
BK-PSL012L-A0300AS; BK-PSL012L-AxxxxA
(‘xxxx’=0200-1100 indicates rated output current
(I_{rated}) 200-1100mA, in steps of 10mA)

Description of Object:

Rated Input Voltage: 200-240VAC/DC or 200-240VAC
Rated Frequency: 0/50/60Hz or 50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection Class: II

Tested according to:

EN IEC 55015:2019/A11:2020
EN IEC 61000-3-2:2019/A1:2021
EN 61000-3-3:2013/A2:2021
EN IEC 61547:2023

Page 2 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.





China

Attestation of Conformity

No. E8AUK 089086 0433 Rev. 01

Model No.	Rated Input Current (A) Max.	Output Voltage (VDC)	I _{rated} (mA)	U _{out} (VDC)	P _{rated} (W) Max.
BK-PSL042-A1100AS BK-PSL042-B1100AS BK-PSL042L-A1100AS	0.24	28-42	500	54	21.00
		28-42	550		23.10
		28-42	600		25.20
		28-42	650		27.30
		28-42	700		29.40
		28-42	750		31.50
		28-42	800		33.60
		28-42	850		35.70
		28-42	900		37.80
		28-42	950		39.90
		28-42	1000		42.00
		28-40	1050		42.00
		28-38	1100		41.80
BK-PSL042-AxxxxA BK-PSL042-BxxxxA BK-PSL042L-AxxxxA	0.24	28-42	500-800	54	33.60
		28-42	810-950		39.90
		28-42	960-1000		42.00
		28-40	1010-1050		42.00
		28-38	1060-1100		41.80
BK-PSL022-A0500AS BK-PSL022L-A0500AS	0.12	28-42	300	54	12.60
		28-42	350		14.70
		28-42	400		16.80
		28-42	450		18.90
		28-42	500		21.00
BK-PSL022-AxxxxA BK-PSL022L-AxxxxA	0.12	28-42	300-500	54	21.00
BK-PSL012L-A0300AS	0.07	28-42	200	54	8.40
		28-42	250		10.50
		28-42	300		12.60
BK-PSL012L-AxxxxA	0.07	28-42	200-300	54	12.60

Page 3 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

