



Product Service

Attestation of Conformity

No. N8A 089086 0644 Rev. 00

Holder of Attestation: **BOKE Drivers Co., Ltd.**
 2nd and 3rd Floor, No.51, Xihuan 5th Road
 South District
 528455 Zhongshan City, Guangdong
 PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic controlgear for LED modules
(LED Driver)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 211-901886-000

Date, 2025-06-23

(Taylor Yao)

Page 1 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 089086 0644 Rev. 00

Model(s):

BK-BPL040S-AHC1050AS; BK-BPL040S-AHCXXXXAS;
BK-BPL040S-AHCXXXXA; BK-DPL036S-AHC0900AD;
BK-DPL036S-AHC0900ADP; BK-DPL036S-AHC0900ADN;
BK-BPL036S-AHC0900AN; BK-DPL036S-AHCXXXXAD;
BK-DPL036S-AHCXXXXADP; BK-DPL036S-AHCXXXXADN;
BK-BPL036S-AHCXXXXAN; BK-DCL010S-AHA0700ADN;
BK-DCL010S-AHAXXXXADN; BK-BCL010S-AHA0700AN;
BK-BCL010S-AHAXXXXAN
(‘XXXX’=0100-1050 indicates rated output current (I_{rated}) 0.10-1.05A, in steps of 0.01A)

Brand:**BOKE****Parameters:**

Rated Input Voltage: 200-240V AC/DC
Rated Frequency: 0/50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection against Electric Shock: Class II (with endcap); SELV
Degree of Protection: IP20 (with endcap)
Method of Installation: Independent (with endcap);
Built-in (without endcap)
Type of Output: Constant current type
ta: See below table for details
tc: See below table for details

**Tested
according to:**

EN 61347-2-13:2014/A1:2017
EN 61347-1:2015/A1:2021
EN 62493:2015/A1:2022

Page 2 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 089086 0644 Rev. 00

Model	Rated Input Current (A) Max.	P _{rated} (W) Max.	Output Voltage (VDC)	I _{rated} (mA)	U _{out} (VDC)	ta (°C)	tc (°C)
BK-BPL040S-AHC1050AS	0.23	14.70	3-49	300	59	45 (Po≤ 40W, Io≤ 1050mA) 50 (Po≤ 34.2W, Io≤ 950mA) 60 (Po≤ 25.2W, Io≤ 700mA)	90
		17.15	3-49	350			
		19.60	3-49	400			
		22.05	3-49	450			
		24.50	3-49	500			
		26.95	3-49	550			
		29.40	3-49	600			
		31.85	3-49	650			
		34.30	3-49	700			
		36.75	3-49	750			
		36.00	3-45	800			
		38.25	3-45	850			
		39.60	3-44	900			
		39.90	3-42	950			
		40.00	3-40	1000			
		39.90	3-38	1050			
BK-BPL040S-AHCXXXXAS	0.23	4.9-40.00	3-49	100-1040	59	45 (Po≤ 40W, Io≤ 1040mA) 50 (Po≤ 34.2W, Io≤ 950mA) 60 (Po≤ 25.2W, Io≤ 700mA)	90
BK-BPL040S-AHCXXXXA	0.23	4.9-40.00	3-49	100-1050	59	45 (Po≤ 40W, Io≤ 1050mA) 50 (Po≤ 34.2W, Io≤ 950mA) 60 (Po≤ 25.2W, Io≤ 700mA)	90
BK-DPL036S-AHC0900AD BK-DPL036S-AHC0900ADP	0.21	7.50	6-50	150	59	50	90
		10.00	6-50	200			
		12.50	6-50	250			
		15.00	6-50	300			
		17.50	6-50	350			
		20.00	6-50	400			
		22.50	6-50	450			
		25.00	6-50	500			
		27.50	6-50	550			
		30.00	6-50	600			
		32.50	6-50	650			
		35.00	6-50	700			
		36.00	6-48	750			
		36.00	6-45	800			
		35.70	6-42	850			
		36.00	6-40	900			
BK-DPL036S-AHC0900ADN	0.21	36.00	6-50	100-900	59	50	90
BK-BPL036S-AHC0900AN	0.21	36.00	6-50	100-900	59	50	90

Page 3 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 089086 0644 Rev. 00

BK-DPL036S-AHCXXXXAD BK-DPL036S-AHCXXXXADP BK-DPL036S-AHCXXXXADN BK-BPL036S-AHCXXXXAN	0.21	5-36.00	6-50	100-890	59	50	90
BK-DCL010S-AHA0700ADN	0.08	10	2.5-42	100-700	59	50 (Po≤ 10W, Io≤ 700mA) 60 (Po≤ 7.2W, Io≤ 600mA)	85
BK-DCL010S-AHAXXXXADN	0.08	4.2-10	2.5-42	100-690	59	50 (Po≤ 10W, Io≤ 690mA) 60 (Po≤ 7.2W, Io≤ 600mA)	85
BK-BCL010S-AHA0700AN	0.08	10	3-42	100-700	59	50 (Po≤ 10W, Io≤ 700mA) 60 (Po≤ 7.2W, Io≤ 600mA)	85
BK-BCL010S-AHAXXXXAN	0.08	4.2-10	3-42	100-690	59	50 (Po≤ 10W, Io≤ 690mA) 60 (Po≤ 7.2W, Io≤ 600mA)	85

Page 4 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.